



**GOVERNMENT OF TELANGANA  
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT  
NO OBJECTION CERTIFICATE**



Ack. No.:	68410002017			
NOC:	000435/OCCU/Rangareddy/2017			
NOC TYPE:	OCCUPANCY*			
Valid Upto:	24-07-2022			
Applicant Details:	Bodhi Tree Educational society.SY.no24/E&25/A/E.Meerpeta village saroor nagar mandal Ranga Reddy			
Building for which NOC issued:	SANTINOS GLOBAL SCHOOL (BODHI TREE EDUCATIONAL SOCIETY),Bodhi Tree Educational society.SY.no24/E&25/A/E.Meerpeta village saroor nagar mandal Ranga Reddy,Meerpeta,Saroor nagar,Rangareddy			
Concessions in Setbacks Given in Lieu of Land Surrendered in Road Widening:	No			
Plot Area (Sq. Mtrs):	5275.00	Height ( Metres): 12.45		
Open Spaces (Metres):	North: 6.00	South: 6.00	East: (F) 6.00	West: 6.00
No. of Floors:0 Cellars, 0 Stilts, 1 Ground, 0 Mezzanines, 3 Floors, 1 Terrace	Occupancy Type: EDUCATIONAL B-1 Schools up to senior secondary level			
Total Built-up Area (Sq.Mtrs):	7207.00	Staircases:	No. of Staircases Required/Proposed:	4
Fees Paid (Rs.):	7207		Aggregate Width Required/Proposed (Metres):	10.80

**Minimum Fire Fighting Installations Provided as per Table 23, Part-IV of NBC, 2005:**

Fire Extinguisher:	40	Hose Reel:	8	Wet Riser:	0
Down Comer:	0	Yard Hydrant:	1	Automatic Sprinkler System:	0
Manually Operated Electric Fire Alarm Systems:	8	Terrace Tank (Litres):	25000		
Automatic Detection and Alarm System:	0	Underground Static Water Storage Tank (Litres):	0		

Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm<sup>2</sup> at Terrace Level

Type	Quantity	(Capacity in Litres/min)
Electrical	0	0
Diesel	0	0
Jockey	0	0

Fire Pump at the Terrace Tank Level with Minimum Pressure of 2.0 kg/cm<sup>2</sup>

(Capacity in Litres/min)
900

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"  
For details and conditions of No Objection Certificate for Occupancy, refer overleaf.

*[Signature]*  
Correspondent,  
**SANTINOS GLOBAL SCHOOL**  
Rd # 1, New Nandi Hills, Colony,  
Meerpeta, Hyderabad, T.S.-500 097.

*[Signature]*  
Principal,  
**SANTINOS GLOBAL SCHOOL**  
Rd # 1, New Nandi Hills, Colony,  
Meerpeta, Hyderabad, T.S.-500 097.



GOVERNMENT OF TELANGANA  
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT  
NO OBJECTION CERTIFICATE



The No Objection Certificate for Occupancy is issued subject to following conditions:

- The applicant should follow the Serial No. 1, 4 of Form No.18 [See Rule 15(1) (f)] of Telangana Fire and Emergency Operations and Levy of Fee Rules, 2006.
- In pursuance of the orders of the Hon'ble High Court mentioned above at Sl.No. 1 of Form No.18 and on the basis of the recommendations of the building inspection committee, this No Objection Certificate for Occupancy is issued.
- Any person violating the conditions of a No Objection Certificate shall be liable to be proceeded against under the provisions of Fire Service Act, 1999.
- The Owner/Occupier may please note that, the department will conduct surprise inspections to verify the satisfactory working condition of the fire safety systems. During the inspection, if any violation of No Objection Certificate for Occupancy conditions/non-functioning of fire safety systems is noticed, prosecution will be launched on the Owner/Occupier as per the provisions of Fire Service Act, 1999.
- It is the responsibility of the builder/management to apply for Renewal of No Objection Certificate for Occupancy duly remitting the user charges as per G.O.Ms.No.71, (Home Prisons-A) Dep., dated: 01-04-2010, two months before expiry of this No Objection Certificate.
- The floor wise built-up areas of the building are as follows:

FloorType	BuildUpArea
Ground	1717.00
1st Floor	1830.00
2nd Floor	1830.00
3rd Floor	1830.00
Terrace	0.00
Total	7207.00

Correspondent,  
SANTINOS GLOBAL SCHOOL  
Rd # 1, New Nandi Hills, Colony,  
Meerpet, Hyderabad, T.S.-500 097.

Principal,  
SANTINOS GLOBAL SCHOOL  
Rd # 1, New Nandi Hills, Colony,  
Meerpet, Hyderabad, T.S.-500 097.